CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



FIR

LISTING No. 7165-0559:137 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Silent Knight Security, 7550 Meridian Circle, Maple Grove, MN 55369

Contact: Michael McIsaac (763) 493-6400 FAX (763) 391-5464

DESIGN: Model SK-5208 fire alarm control unit. Power-limited, automatic, manual, remote station,

central station, waterflow, Releasing Device Service, and sprinkler supervisory services. Refer to listee's data sheet for additional detailed product description and operational

considerations. System components:

SK5208 Control Unit

SK-5220 Direct Connect Module SK-5280 Status Display Module SK-5217 Zone Expander SK-5235 Remote Annunciator

SK-2190 Enclosure SK-7181 Zone Converter

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes & ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units for use with separately listed compatible initiating and

indicating devices.

This control unit can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 2002 Edition. Refer

to manufacturer's Installation Manual for details.

This control unit meets the requirements of UL-864, 9th Edition Standards.

NOTE:

1. For the Alarm Verification Feature (delay of fire alarm), the maximum Retard/Reset/Restart shall not exceed 30 seconds.

2. Burglary and other non-fire functions were not examined.

08-17-2006 jw



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 6, 2008 Listing Expires June 30, 2009

Authorized By: **BEN HO**, Chief

Fire Engineering Division